



ISOMETRIC VIEW

NOTES:

1. ALL METER LOCATIONS TO BE IN BASEMENTS AND NOT CRAWL SPACES. FOR PARTIAL BASEMENTS SEE SHEET NO. 50
2. SEE SHEET NO. 45 FOR GENERAL METER NOTES.
3. A FLOOR DRAIN SHALL BE PLACED NEAR THE METER INSTALLATIONS FOR NEW SERVICES. A FLOOR DRAIN IS NOT REQUIRED FOR A METER IN EXISTING SERVICES.
4. ALL IRRIGATION OR SPRINKLER VALVES AND PRV'S SHALL BE UPSTREAM FROM THE OUTLET GATE VALVE.
5. METERS REQUIRE ELECTRONIC DIGITAL ENCODER OR MECHANICALLY ENCODED REGISTER WITH AN ITRON ERT MODEL 40W WITH A 15FT. CABLE.



ELEVATION



PLAN

DENVER WATER

1600 West 12th Avenue • Denver, Colorado 80204
Phone (303) 628-6000 • Telecopier No. (303) 628-6851

**TYPICAL INSIDE SETTING FOR
3/4" AND 1" METER WITH AMR.**

Scale: NONE Date: AUGUST 1995

Drawn: C.B.B. Tr: Ck:

Approved: Dr. 127 No. 35